

Specifiers: Click on the ¶ icon in the WORD toolbar to reveal detailed instructions

(Specifier Note: The purpose of this guide specification is to assist the specifier in correctly specifying metal wall panels and their installation. The specifier needs to edit these guide specifications to fit the needs of each specific project. Contact a Morin representative to assist in appropriate product selections. Throughout the guide specification, there are Specifier Notes to assist in the editing of the file. The term Architect is used throughout these guide specifications and may be revised to read "Design Professional", "Engineer", "Owner" or other appropriate designation as required for specific projects.

References have been made within the text of the specification to current MasterFormat Section numbers and titles, specifier needs to coordinate these numbers and titles with sections included for the specific project. Brackets []; "AND/OR"; and "OR" have been used to indicate when a selection is required, in most cases the first option is the standard feature, and optional features are indicated in brackets. Some options may require additional lead-time, if this is a consideration; contact a Morin representative for assistance.)

SECTION 07 42 13.26
PERFORATED METAL WALL PANELS
Morin Metal Panels
Exposed Fastener Perforated Metal Wall Panels

PART 1 - GENERAL

1.1 SECTION INCLUDES

- A. Exposed fastener single skin perforated metal wall panels used as a screen wall.
- B. *[Exposed fastener soffit panels.]*
- C. Accessories including fasteners, perimeter trim and penetration treatments.

(Specifier Note: COORDINATE References Article and delete ASTM and DIN references that are deleted in the body of the spec during editing.

1.2 REFERENCES

- A. ASTM International
 - 1. ASTM A240; Standard Specification for Chromium and Chromium-Nickel Stainless Steel Plate, Sheet, and Strip for Pressure Vessels and for General Applications.
 - 2. ASTM A653; Standard Specification for Steel Sheet, Zinc Coated (Galvanized) or Zinc Iron Alloy Coated (Galvannealed) by the Hot Dip Process.
 - 3. ASTM A666; Standard Specification for Annealed or Cold-Worked Austenitic Stainless Steel Sheet, Strip, Plate, and Flat Bar.
 - 4. ASTM B209; Standard Specification for Aluminum and Aluminum-Alloy Sheet and Plate.

5. ASTM B370; Standard Specification for Copper Sheet and Strip for Building Construction.
6. ASTM C645 – Standard Test Method for Nonstructural Steel Framing Members.
7. ASTM E1592; Standard Test Method for Structural Performance of Sheet Metal Roof and Siding Systems by Uniform Static Air Pressure Difference.

B. German Institute for Standardization (DIN)

1. DIN EN988; Specifications for zinc and zinc alloy rolled flat products for building.
2. DIN EN1179; Zinc and Zinc alloys – Primary Zinc.

1.3 SUBMITTALS

(Specifier Note: DELETE Submittal Procedures paragraph when not required. Coordinate requirements with Section 01 33 00 – Submittal Procedures.)

- A. Refer to Section [01 33 00 Submittal Procedures] [Insert section number and title].
- B. Product Data: Submit manufacturer current technical literature for each type of product.
- C. Delegated Design: Design metal wall panel assembly, submit comprehensive engineering analysis by a qualified professional engineer, using performance requirements and design criteria indicated.
- D. Shop Drawings - Submit detailed drawings showing:
 1. Profile
 2. Gauge of panel
 3. Location, layout and dimensions of panels
 4. Location and type of fasteners
 5. Shape and method of attachment of all trim
 6. Locations and type of sealants
 7. Installation sequence.
 8. Other details as may be required for a weathertight installation
- E. Samples: Provide nominal 3 x 5 inch of each color indicated. [Provide panel width by 10 inches long minimum] [Insert size].

(Specifier Note: DELETE LEED submittal requirements when project is not pursuing LEED certification. Related to Innovation and Design process (ID) credits; contact Kingspan for assistance in developing credits where their products can assist in obtaining. LEED-NC v2.2 credits are in red LEED-NC v3 credits are in red bold.)

F. LEED Submittals:

1. Material and Resources (MR)

- a. Product Certificates for Credit **[MR 4]** **[MR 4.1[and Credit MR 4.2]]**: For products having recycled content, documentation indicating percentages by weight of postconsumer and preconsumer recycled content.

G. Quality Assurance Submittals

1. Manufacturer Erection Instructions: Provide manufacturer's written installation instructions including proper material storage, material handling, installation sequence, panel location(s), and attachment methods, details and required trim and accessories.

H. Closeout Submittals

1. Refer to Section **[01 78 00 Closeout Submittals]** **[Insert section number and title]**.

1.4 ADMINISTRATIVE REQUIREMENTS

- A. Pre-installation meeting: Conduct a pre-installation meeting at the job site attended by Owner, Architect, Manufacturer's Technical Representative, Panel Installer, and Contractors of related trades. Coordinate structural support requirements in relation to wall panel system, installation of any separate air/water barriers, treatment of fenestration, and other requirements specific to the project.

1.5 QUALITY ASSURANCE

- A. Manufacturer Qualifications: Manufacturer shall have a minimum of ten (10) years experience in the production of metal wall panels. Manufacturer shall demonstrate past experience with examples of projects of similar type and exposure.
- B. Installer Qualifications: Installer shall be authorized by the manufacturer and the work shall be supervised by a person having successfully completed a manufacturer training seminar regarding proper installation of the specified product.

1.6 DELIVERY, STORAGE AND HANDLING

- A. Refer to Section **[01 60 00 Product Requirements]** **[Insert section number and title]**.

- B. Deliver panel materials and components in manufacturer's original, unopened, undamaged packaging with identification labels intact.
- C. Store wall panel materials on dry, level, firm, and clean surface. Elevate one end of bundle to allow moisture run-off, cover and ventilate to allow air to circulate and moisture to escape.

1.7 WARRANTY

- A. Refer to Section **[01 78 36 Warranties]** **[Insert section number and title]**.
- B. Material Warranty: Standard form in which manufacturer agrees to repair or replace items that fail in materials or workmanship within specified warranty period. The items covered by the warranty include structural performance.
 - 1. Warranty Period: Two (2) years from date of Substantial Completion.

PART 2 - PRODUCTS

(Specifier Note: Product Information is proprietary to Morin Metal Panels. If additional products are required for competitive procurement, contact Morin Metal Panels for assistance.)

2.1 MANUFACTURER

- A. Morin; a Kingspan Group Company; 685 Middle Street, Bristol, Connecticut 06010-8416; 1-800-640-9501 (Toll Free); (www.morincorp.com)
- B. Basis of Design: "Exposed Fastener Wall Panels".

(Specifier Note: DELETE or COORDINATE Substitution Limitations paragraph if substitutions, are addressed in Section 01 21 00 – Substitution Procedures.)

- C. Substitution Limitations:
 - 1. Submit written request for approval of substitutions to the Architect **[a minimum of [14] days prior to the date for receipt of bids]** **[Insert time period]**. Include the following information:
 - a. Name of the materials and description of the proposed substitute.
 - b. Drawings, cut sheets, performance and test data.
 - c. List of projects similar scope and photographs of existing installations.
 - d. Other information necessary for evaluation.
 - 2. After evaluation by Architect, approval will be issued via addendum. No verbal approval will be given.

3. Substitutions following award of contract are not allowed except as stipulated in Division 01 – General Requirements.

2.2 PERFORMANCE REQUIREMENTS

- A. Structural Performance: Provide metal wall panel systems designed to resist the following. Testing shall be done based on ASTM E1592:
 1. Wind Loads: Determine loads based on the following minimum design wind pressures:
 - a. Uniform pressure [Insert design wind pressure] [as indicated on Drawings].
 2. Deflection Limits: Perforated metal wall panel assemblies shall withstand horizontal deflections no greater than $[L/90]$ [Insert deflection] of the span.

2.3 WALL PANEL MATERIALS

(Specifier Note: Choose one of the following materials. Aluminum, Stainless Steel, Copper or Rheinzink.)

- A. Aluminum:
 1. Coil Stock meeting ASTM B209; Alloy and temper as required for forming operations.
 2. Thickness: [0.040] [0.050] inch.

OR

- B. Stainless Steel Sheet:
 1. ASTM A240 or ASTM A666, Type 304, dead soft, fully annealed.
 2. Gauge: [22] [20]

OR

- C. Copper:
 1. Sheet stock meeting ASTM B370, cold-rolled, H00 or H01 temper.
 2. Weight: 20 ounce per square foot.

OR

- D. Rheinzink Sheets:
 1. Sheet stock meeting DIN EN1179, consisting of Zinc with copper and titanium additives in accordance with DIN EN988.
 2. Thickness: 1.0 mm

2.4 WALL PANELS

A. Wall Panel Descriptions:

1. Panel Width: 24 inches
2. Profile: [O-24] [O-24S] [O-24W]
3. Profile Thickness: 4 inches

OR

4. Panel Width: 28 inches
5. Profile: [BR-28] [BR-28S]
6. Profile Thickness: 1 ½ inch

OR

7. Panel Width: 30 inches
8. Profile: E-30
9. Profile Thickness: 1 inch

OR

10. Panel Width: 30 inches
11. Profile: DF-30
12. Profile Thickness: ¾ inch

OR

13. Panel Width: 36 inches
14. Profile: MR-36
15. Profile Thickness: 3 inch

OR

16. Panel Width: 36 inches
17. Profile: [Y-36] [BR9-36]
18. Profile Thickness: 1 1/2 inch

OR

19. Panel Width: 36 inches
20. Profile: [E-36] [VB-36]
21. Profile Thickness: 1 inch

OR

22. Panel Width: 34 1/8 inches
23. Profile: VB-34
24. Profile Thickness: 1 ¾ inch

OR

25. Panel Width: [35] [29] inches
26. Profile: [BR7-35] [Y-29]
27. Profile Thickness: 1 ½ inch

OR

28. Panel Width: 40 inches
29. Profile: E8-40
30. Profile Thickness: 1 inch

OR

31. Panel Width: [37 5/16] [29 5/8] inches
32. Profile: [C-37-7/8] [C-29-7/8]
33. Profile Thickness: 7/8 inch

OR

34. Panel Width: 40 inches
35. Profile: C-40-1/2
36. Profile Thickness: ½ inch

(Specifier Note: DELETE Perforation Patterns NOT used.)

37. Texture: Perforated.
 - a. [Perforation Pattern; 1/8 inch holes: [40 percent open area – 3/16 inch hole spacing] [30 percent open area – 7/32 inch hole spacing] [23 percent open area – 1/4 inch hole spacing] [10 percent open area – 3/16 inch hole spacing]]
 - b. [Perforation Pattern; 3/16 inch holes: 33 percent open area – 5/16 inch hole spacing]
 - c. [Perforation Pattern; 1/4 inch holes: 23 percent open area – 1/2 inch hole spacing]
 - d. [Perforation Pattern; 3/8 inch holes: 40 percent open area – 9/16 inch hole spacing]

2.5 ACCESSORIES

- A. Wall panel accessories: Provide accessories as required for a complete installation. Accessories shall be as indicated on approved shop drawings and per manufacturer's approved standard details. Match material and finish of metal wall panels.
 1. Fasteners: Fasteners with neoprene washers as recommended by manufacturer. Fastener head shall match exposed panel color.

2. Closure Strips:

- a. Closed Cell Closure Strips: Provide minimum 1 inch thick matching metal wall panel profile.
- b. Metal Profile Closure Strips: Shall be fabricated from same gauge, material and finish as metal panel.

(Specifier Note: SELECT fabricated sheet metal trim or extruded aluminum trim as appropriate for project requirements. Aluminum trim is factory stocked for 1 and 3 inch panel depths. Custom trim depths can be ordered.)

(Specifier Note: DELETE Flashing and trim materials if products are provided under Section - 07 62 00 - Sheet Metal Flashing and Trim.)

B. Trim:

1. [Fabricate trim from same material and material thickness as wall panels. Finish to match metal wall panels.]

OR

2. [Extruded trim: Shall be ¾ inch deep extruded aluminum 6063-T5 alloy with spray applied PVF coating in same color as metal wall panel.]
3. Locations include, but are not limited to the following: Drips, sills, jambs, corners, framed openings, parapet caps, reveals and fillers.
4. [Trim shall be provided under Section 07 62 00 - Sheet Metal Flashing and Trim".]

C. Metal Framing:

(Specifier Note: EDIT metal framing requirements to suit Project needs.)

1. General: ASTM C645, cold-formed metallic-coated steel sheet, [ASTM A653, G40 hot-dip galvanized] [ASTM A653, G60 hot-dip galvanized].
2. Hat-Shaped, Rigid Furring Channels:
 - a. Nominal Thickness: [As indicated on Drawings] [0.025 inch] [0.040 inch] [Insert thickness].
 - b. Depth: [As indicated on Drawings] [7/8 inch] [1-1/2 inches] [Insert depth].
3. Cold-Rolled Furring Channels: Minimum 1/2-inch wide flange.
 - a. Nominal Thickness: [As indicated on Drawings] [0.064 inch] [Insert thickness].
 - b. Depth: [As indicated on Drawings] [3/4 inch] [Insert depth].

2.6 FABRICATION

- A. Metal wall panels shall be formed to lap with edges of adjacent panels which are then mechanically attached through panel to supports using fasteners with a neoprene washer. Fastener head shall match wall panel finish.

B. Panels shall be factory formed. Field formed panels are not acceptable.

(Specifier Note: Select curved wall panels if required by project design.)

C. [Curved wall panels: Panels shall be factory curved as approved by manufacturer.]

(Specifier Note: DELETE trim accessories fabrication paragraph if provided under Section 07 62 00 - Sheet Metal Flashing and Trim" or if extruded aluminum trim is used.)

D. [Trim Accessories: Fabricate steel trim accessories to comply with recommendations outlined in SMACNA's "Architectural Sheet Metal Manual".]

2.7 FINISHES

A. Aluminum:

(Specifier Note: Aluminum panels come in a painted finish or aggregate finish. Select finish to meet project requirements.)

(Specifier Note: Custom colors require a minimum quantity order of 2, 500 linear feet.)

1. Finish and Color:

a. Color: [Selected from current Morin Metal Wall Panel color chart] [Custom color as selected by Architect] [Color indicated].

(Specifier Note: Panels used in a screen wall application shall have factory finish on both sides of panel.)

b. Panels shall be finished on exterior and interior surfaces.

c. Finish System:

(Specifier Note: Choose one of the following paint systems. 1.0 mil Two Coat system (Solid Color) is most commonly used. The 1.0 mil Mica color coat and the 1.5 mil Metallic color coat systems are chosen if Premium Colors are desired. Use the 2.4 mil Three Coat system if a harsh environment is anticipated (such as industrial facilities or in coastal regions).

- 1) [1.0 mil. Fluoropolymer (PVDF) Two Coat system: 0.2 mil primer with 0.8 mil Kynar 500 (70 percent) SOLID color coat.]
- 2) [1.0 mil. Fluoropolymer (PVDF) Two Coat system: 0.2 mil primer with 0.8 mil Kynar 500 (70 percent) MICA color coat.]
- 3) [1.5 mil. Fluoropolymer (PVDF) Three Coat system: 0.2 mil primer with 0.8 mil Kynar 500 (70 percent) METALLIC color coat and .5 mil clear coat.]
- 4) [2.4 mil. Fluoropolymer (PVDF) Three Coat system: 0.8 mil primer with 0.8 mil Kynar 500 (70 percent) SOLID color coat and 0.8 mil clear coat.]

OR

- B. Stainless Steel: [2D (dull, cold rolled)] [2B (bright, cold rolled)] [4 (polished directional satin)]

OR

- C. Copper: Natural

OR

- D. Rheinzink: [Bright Rolled – mill finish] [Pre-weathered “Graphite-Gray”] [Pre-weathered “Blue-Gray”]

PART 3 - EXECUTION

3.1 EXAMINATION

- A. Provide field measurements to manufacturer as required to achieve proper fit of the metal wall panels to building envelope. Measurements shall be provided in a timely manner so that there is no impact to construction or manufacturing schedule.

(Specifier Note: COORDINATE Supporting steel tolerances with appropriate structural steel, metal fabrication, and metal framing sections.)

- B. Supporting Steel: Verify that Supporting Steel members are installed within the following tolerances:
 - 1. Plus or minus 1/8 inch in 5 feet in any direction along plane of framing.
 - 2. Plus or minus 1/4 inch cumulative in 20 feet in any direction along plane of framing.
 - 3. Plus or minus 1/2 inch from framing plane on any elevation.
 - 4. Plumb or level within 1/8 inch at all changes of transverse for performed corner panel applications.
 - 5. Verify that bearing support has been provided behind vertical joints of horizontal panel systems and vertical joints of horizontal panel systems. Width of support shall be as recommended by manufacturer.
- C. Examine individual panels upon removing from the bundle; notify manufacturer of panel defects. Do not install defective panels.

3.2 PANEL INSTALLATION

(Specifier Note: DELETE installation paragraphs not project specific.)

- A. Installation shall be in accordance with manufacturer’s installation guidelines and recommendations.

- B. Install panels plumb, level, and true-to-line to dimensions and layout indicated on approved shop drawings.
- C. Cutting and fitting of panels shall be neat, square and true. Torch cutting is prohibited.

3.3 TRIM INSTALLATION

- A. Place trim and trim fasteners only as indicated per details on the approved shop drawings.

3.4 CLEANING AND PROTECTION

- A. Remove protective film immediately after installation.
- B. Touch-up, repair or replace metal panels and trim that have been damaged.
- C. After metal wall panel installation, clear weep holes and drainage channels of obstructions, dirt, and sealant.

END OF SECTION

DISCLAIMER:

Morin Metal Panels Guide Specifications have been written as an aid to the professionally qualified Specifier and Design Professional. The use of this Guideline Specification requires the sole professional judgment and expertise of the qualified Specifier and Design Professional to adapt the information to the specific needs for the Building Owner and the Project, to coordinate with their Construction Document Process, and to meet all the applicable building codes, regulations and laws. MORIN METAL PANELS EXPRESSLY DISCLAIMS ANY WARRANTY, EXPRESSED OR IMPLIED, INCLUDING THE WARRANTY OF MERCHANTABILITY OR FITNESS FOR PARTICULAR PURPOSE OF THIS PRODUCT FOR THE PROJECT.